

CERTIFICATE

Fire extinguishers

This is to confirm that the below stated **“KZWM OGNIОCHRON” DIN EN 3 fire extinguisher** with 2 kg ABC powder is approved in accordance with DIN EN 3-7 as well as on basis of the available test reports for fire extinguishing purposes for the fire class **A, Band C** according to DIN EN 2 under the following certification number:

SP 64/09

Test report according to CEN/TR 14922 : 2004-12 No.: 2009-F-0615/OG 03

Holder of certificate: **KZWM OGNIОCHRON S.A., ul. Krakowska 83c, 34-120 Andrychow, Poland**

Manufacturer: **KZWM OGNIОCHRON S.A., ul. Krakowska 83c, 34-120 Andrychow, Poland**

Model name of the fire extinguisher: **GP-2x ABC** Drawing No.: **GP2-030-00**
Component list No.: **GP2-030-00**

Fire extinguishing medium: **FUREX ABC plus** Operation device: **Operation valve lever**
Cert. No. PL-3/82

Propellant: **Nitrogen, 15 bar/20 °C** Special detail: **Nozzle Ø 3,5 mm acc. to drawing no. GP2-030-02**

Test fire rating: **13 A and 89 B according to DIN EN 3-7** Temperature operation range: **- 30 °C to 60 °C**

Information: **-**

The fire extinguisher is tested in accordance with DIN EN 3. Conformity to DIN EN 3 is confirmed.

The given certification number **SP 64/09** is to state in section 4 of the extinguisher label according to DIN EN 3-7.

This certificate is valid for fire extinguishers only, those comply with the submitted documents and test samples.


This certificate is valid for fire extinguishers only, those are subjected to a quality assurance system during manufacture.

The quality assurance system shall include the valid requirements of the standard DIN EN 3 concerning factory production control.

The holder of certificate is entitled to put up the above stated certification number on the fire extinguisher as long as the results of our regular inspection of manufacture in accordance with DIN EN 3 are satisfactory.

The above mentioned European standards relate to the editions which were valid at the date of this certification.

2009-07-22



Grad. Eng. A. Ullmann
Manager of the certification office



MPA Dresden GmbH
Fuchsmühlenweg 6F
D-09599 Freiberg
Tel.: +49(0)3731-2 03 93-0
Fax: +49(0)3731-2 03 93-110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
Internet: www.mpa-dresden.de
E-Mail: info@mpa-dresden.de

Kreissparkasse Freiberg
Poststraße 1a
D-09599 Freiberg
Kto.: 3115024672
BLZ: 870 520 00

USt-IdNr.: DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX