

CERTIFICATE

Fire extinguishers

This is to confirm that the below stated "KZWM OGNIOPHON" DIN EN 3 fire extinguisher with 5 kg carbon dioxide is approved in accordance with DIN EN 3-7 as well as on basis of the available test reports for fire extinguishing purposes for the fire class **B** according to DIN EN 2 under the following certification number:

SP 66/09

Test report according to CEN/TR 14922 : 2004-12 No.: 2009-F-0615/OG 05

Holder of certificate: KZWM OGNIOPHON S.A., ul. Krakowska 83c, 34-120 Andrychow, Poland

Manufacturer: KZWM OGNIOPHON S.A., ul. Krakowska 83c, 34-120 Andrychow, Poland

Model name of the
fire extinguisher: GS-5x B

Drawing No.: GS-4.00
Component list No.: GS-4.00

Fire extinguishing
medium: carbon dioxide
Cert. No. -

Operation device: grip lever

Propellant: -

Special detail: Snow horn acc. to drawing
no. 3-VL-920040108

Test fire rating: 89 B according to DIN EN 3-7

Temperature
operation range: - 20 °C to 60 °C

Information: other brand name „GÖCKLER“

The fire extinguisher is tested in accordance with DIN EN 3. Conformity to DIN EN 3 is confirmed.

The given certification number **SP 66/09** is to state in section 4 of the extinguisher label according to DIN EN 3-7.

This certificate is valid for fire extinguishers only, those comply with the submitted documents and test samples.


This certificate is valid for fire extinguishers only, those are subjected to a quality assurance system during manufacture.

The quality assurance system shall include the valid requirements of the standard DIN EN 3 concerning factory production control.

The holder of certificate is entitled to put up the above stated certification number on the fire extinguisher as long as the results of our regular inspection of manufacture in accordance with DIN EN 3 are satisfactory.

The above mentioned European standards relate to the editions which were valid at the date of this certification.

2009-07-09


Grad. Eng. A. Ullmann
Manager of the certification office



MPA Dresden GmbH
Fuchsmühlenweg 6F
D-09599 Freiberg
Tel.: +49(0)3731-2 03 93-0
Fax: +49(0)3731-2 03 93-110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
Internet: www.mpa-dresden.de
E-Mail: info@mpa-dresden.de

Kreissparkasse Freiberg
Poststraße 1a
D-09599 Freiberg
Kto.: 3115024672
BLZ: 870 520 00

USt-IdNr.: DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX

1st SUPPLEMENT TO CERTIFICATE

Fire extinguishers

Certificate no. **SP 66/09**

dated 9th July 2009

Designation of fire extinguisher: „KZWM OGNIОCHRON“ DIN EN 3 fire extinguisher
with 5 kg carbon dioxide

Holder of certificate/Manufacturer: KZWM OGNIОCHRON S.A., ul. Krakowska 83c,
34-120 Andrychow, Poland

Model name of extinguisher: GS-5x B

Fire classes according to DIN EN 2: B

Modifications/Supplementations: Temperature operation range - 30 °C to 60 °C
Basis is the supplementary test report no. 2009-F-0615/OG 05.


New model name: –

The fire extinguisher with the above mentioned certification number is suitable for extinction of fires of the fire classes as stated above also with the modifications according to this supplement.

Conformity with standard DIN EN 3 of the modified fire extinguisher is confirmed.

Other regulations of the certificate are not affected by this supplement.

2009-08-03



Grad. Eng. A. Ullmann
Manager of the certification office



MPA Dresden GmbH
Fuchsmühlenweg 6F
D-09599 Freiberg
Tel.: +49(0)3731-2 03 93-0
Fax: +49(0)3731-2 03 93-110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
Internet: www.mpa-dresden.de
E-Mail: info@mpa-dresden.de

Kreissparkasse Freiberg
Poststraße 1a
D-09599 Freiberg
Kto.: 3115024672
BLZ: 870 520 00

USt-IdNr.: DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX