



APRAGAZ

a.s.b.l.
Your Inspection Authority

Member of
CEOC
INTERNATIONAL

Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

KZWM OGNIОCHRON S.A.
ul. Krakowska 83c

34-120 ANDRYCHÓW
POLAND

Y/Ref. :
O/Ref. : CHL/FB/PRODUCT CERTIFICATION/BUILDINGS/OGNIОCHRON/2010-04-15.

Brussels, 15 April 2010 .

APPROVAL CERTIFICATE EN3 – PORTABLE FIRE EXTINGUISHERS FOR BUILDINGS

We hereby declare that the hereafter mentioned extinguishers were type approved according to the requirements of the EN3-7 standards, according to the tests reports and with the hereafter mentioned approval number :

Approval Nr	Mark	Type	Nominal Charge	Fire ratings achieved	EN3-7 test report nr
EN3-10/238	KZWM OGNIОCHRON S.A.	GP-1x ABC	1 kg ABC powder Type "FUREX ABC Standard 20 %"	5 A - 21 B	EN 10706
EN3-10/239	KZWM OGNIОCHRON S.A.	GP-2x ABC	2 kg ABC powder Type "FUREX ABC Plus 40 %"	13 A - 89 B	EN 10707
EN3-10/240	KZWM OGNIОCHRON S.A.	GP-1z BC	1 kg BC powder Type "RENEX BC PLUS"	21 B	EN 10705

The approval is subject to the continued maintenance of the Quality System of the manufacturer in accordance with the relevant requirements of EN3-6.

The manufacturer is authorized to affix the above mentioned approval number on the marking label of the approved corresponding extinguishers as long as the results of our inspections, periodically made according to the requirements of § 5 of the EN3 part 6, are satisfactory.

Nota Bene : additional requirements (i.e. : language of the labels, maintenance requirements, ...) may be made by national regulations and/or quality marks.

The General Manager,


Mr Christian LEPLAT